


# Performance Test Results

Category 6 Patch Panel

**Test Summary: PASS**  
 Tester: Fluke model DTX-1800



**Proven performance with minimum 8.9 dB Headroom @ 250 Mhz!**



TIA Category 6 Permanent Link performance test results

PASS	Worst Case Margin		Worst Case Value	
	MAIN	SR	MAIN	SR
Worst Pair	36-45		36-45	
<b>NEXT (dB)</b>	8.9		8.9	
Freq. (MHz)	229.0		237.5	
Limit (dB)	36.0		35.7	

Item Number: **ICMPP02460**  
 24-Port, CAT 6, 1 rack mount space

